


Agenda

- General
- Chapter 26-31 Change Highlights
- Tornado Loads
- Q&A



Navigating Changes

 Look for grey bars in margins

CHAPTER 26 WIND LOADS: GENERAL REQUIREMENTS

26.1 PROCEDURES

26.1.1 Scope Buildings and other structures, including the main wind force resisting system (MWFRS) and all components and cladding (C&C) thereof, shall be designed and constructed to resist the wind loads determined in accordance with Chapters 26 through 31.

Risk Category III and IV buildings and other structures, including the MWFRS and all C&C thereof, shall also be designed and constructed to resist tornado loads determined in accordance with Chapter 32, as applicable.

The provisions of this chapter define basic wind parameters for use with other provisions contained in this standard.

User Note: A building or other structure designed for wind loads determined exclusively in accordance with Chapter 26 cannot be designated as a storm shelter without meeting additional critical requirements provided in the applicable building code and ICC 500, the ICC/NSSA Standard for the Design and Construction of Storm Shelters. See Commentary Section C26.1.1 for an in-depth discussion on Storm Shelters.

26.1.2.2 Components and Cla buildings and other structures : following procedures:

- 1. Analytical Procedures p appropriate, of Chapter :
- 2. Wind Tunnel Procedure

26.1.3 Performance-Based

buildings and other struct procedures shall be permitted Authority Having Jurisdiction design procedures used shall Section 1.3.1.3.

26.2 DEFINITIONS

The following definitions apply through 31.


APPROVED: Acceptable Jurisdiction.





Errata

- Mistakes happen
- Free download from ASCE Library
- Search "ASCE 7-22 errata"



Supplements

- Important technical changes
 - Must follow code adoption process
- Free download from ASCE Library
- Supplements #1 & #2
 Published

Standard 7-22 Minimum Design Loads and Associated Criteria for Buildings and Other Structures

SUPPLEMENT 2

Chapter 1: General

1.3.1.3 Performance Based Procedures

Structural and nonstructural components and their connections designed with performance-based procedures shall be demonstrated by analysis in accordance with Section 2.3.5 or by analysis procedures supplemented by testing to provide a reliability that is generally consistent with the target reliabilities stinulated in this section.

Structural and nonstructural components subjected to dead, live, environmental, and other loads except earthquake, tsunami, and loads from extraordinary events shall be based on the target reliabilities in Table 1.3-1. Structural systems subjected to earthquake shall be based on the target reliabilities in Table 1.3-2 and 1.3-3. The design of structures subjected to tsunami loads shall be based on the target reliabilities in Table 1.3-4. Structures, components, and systems that are designed for extraordinary events, using the requirements of Section 2.5 for scenarios approved by the Authority Having Jurisdiction, shall be based on the target reliabilities in Table 1.3-5. The analysis procedures used shall account for uncertainties in loading and resistance.

Chapter 2: Combinations of Loads

2.2 SYMBOLS

 A_k = Load or load effect arising from extraordinary event A

D = Dead load

 D_i = Weight of ice

E = Earthquake load

F = Load caused by fluids with well-defined pressures and maximum heights

S2-1

Minimum Design Loads and Associated Criteria for Buildings and Other Structures



General Provisions Chapter 26

Performance Based Wind Design (PBD)

- 26.1.3: Charging language
 - Design shall conform to 1.3.1.3
- ASCE/SEI Prestandard for Performance-Based Wind Design (2019)
 - Prestandard is FREE from ASCE publications
 - Revised prestandard (V1.1) published in 2023

Prestandard for Performance-Based Wind Design

Wind Design

V1.1

American Society of Civil Engineers









Wind Hazard Maps

- ASCE Hazard Tool now free
 - https://ascehazardtool.org/
 - No paper maps in the future?



Wind Hazard Maps

- Special wind regions updated
- Gulf coast hurricane wind speeds revised
- Topographic effects included in Puerto Rico & US Virgin Islands maps






Wind Hazard Maps

Georgia:

Risk Category II Basic Wind Speed					
	7-16	7-22	Change		
Atlanta	107	105	0.96		
Augusta	113	110	0.95		
Macon	109	107	0.96		
Savannah	135	135	1.00		
Valdosta	113	114	1.02		



Topographic Effects

- Section 26.8.1
- Conditions 1 & 2 removed
 - 7-16 required isolated & unobstructed, and significant features
 - More sites will require K_{zt} evaluation
- Clarifying language added for table vs equations



Ground Elevation Factor

- Clarified ground elevation above sea level
- $z_g -> z_e$
- z_g was not intended to be the z_g (gradient height) from velocity pressure coefficient calculations

Table 26.9-1. Ground Elevation Factor, K_e .

Ground Elevation above Sea Level				
ft	m	Ground Elevation Factor, K_e		
<0	<0	See note 2		
0	0	1.00		
1,000	305	0.96		
2,000	610	0.93		
3,000	914	0.90		
4,000	1,219	0.86		
5,000	1,524	0.83		
6,000	1,829	0.80		
>6,000	>1,829	See note 2		

Notes:

- 1. Conservative approximation $K_e = 1.00$ is permitted in all cases.
- 2. Factor K_e shall be determined from Table 26.9-1 using interpolation or from the following formula for all elevations: $K_e = e^{-0.0000362z_e}$ (z_e = ground elevation above sea level, ft); or $K_e = e^{-0.000119z_e}$ (z_e = ground elevation above sea level, m).
- 3. K_e is permitted to be taken as 1.00 in all cases.

Velocity Pressure Coefficients

- Boundary layer profile adjusted
 - Table 26.10-1 & 26.11-1
- Typical structures:
 - Small reduction in K_z for Exposure B & C
 - No change for Exposure D

Table 26.10-1. Velocity Pressure Exposure Coefficients, K_h and K_z .

Height above Ground Level, z or h		Exposure			
ft	m	В	С	D	
0–15	0-4.6	0.57 (0.70)*	0.85	1.03	
20	6.1	0.62 (0.70)*	0.90	1.08	
25	7.6	0.66 (0.70)*	0.94	1.12	
30	9.1	0.70	0.98	1.16	
40	12.2	0.74	1.04	1.22	
50	15.2	0.79	1.09	1.27	
60	18.3	0.83	1.13	1.31	
70	21.3	0.86	1.17	1.34	
80	24.4	0.90	1.21	1.38	
90	27.4	0.92	1.24	1.40	
100	30.5	0.95	1.26	1.43	
120	36.6	1.00	1.31	1.48	
140	42.7	1.04	1.34	1.52	
160	48.8	1.08	1.39	1.55	
180	54.9	1.11	1.41	1.58	
200	61.0	1.14	1.44	1.61	
250	76.2	1.21	1.51	1.68	
300	91.4	1.27	1.57	1.73	
350	106.7	1.33	1.62	1.78	
400	121.9	1.38	1.66	1.82	
450	137.2	1.42	1.70	1.86	
500	152.4	1.46	1.74	1.89	

^{*}Use 0.70 in Chapter 28, Exposure B, when z < 30 ft (9.1 m). Notes:

Velocity pressure exposure coefficient K_z may be determined from the following formula:

For z < 15 ft	$K_z = 2.41 (15/z_g)^{2/\alpha}$
For z < 4.6 m	$K_z = 2.41 (4.6/z_g)^{2/\alpha}$
For 15 ft (4.6 m) $\leq z \leq z_g$	$K_z = 2.41 (z/z_g)^{2/\alpha}$
For $z_g < z \le 3,280$ ft	
(1,000 m)	$K_z = 2.41$

α and z_g are tabulated in Table 26.11-1.

Table 26.11-1. Terrain Exposure Constants.

	Velocity	Velocity pressure		
Exposure	α	α z_g (ft)		
B C D	7.5 9.8 11.5	3,280 2,460 1,935	1/7.5 1/9.8 1/11.5	
Exposure	α	z_g (m)	â	
B C D	7.5 9.8 11.5	1,000 750 590	1/7.5 1/9.8 1/11.5	

 ^{*} z_{min} = Minimum height used to ensure that the equivalent as z_{min}.




Linear interpolation for intermediate values of height z is acceptable

Exposure categories are defined in Section 26.7

Velocity Pressure Coefficients

- Boundary layer profile adjusted
 - Table 26.10-1 & 26.11-1
- Typical structures:
 - Small reduction in K_z for Exposure B & C
 - No change for Exposure D
- Very tall structures:
 - K_z increase up to 20%



Directionality Factor

• K_d moved from Velocity Pressure (q_z) to Pressure Equations

$$q_z = 0.00256K_zK_{zt}K_dK_eV^2 \text{ (lb/ft}^2); V \text{ in mi/h}$$
 (26.10-1)

• MWFRS:
$$p = qK_{\overline{d}}GC_p - q_iK_{\overline{d}}(GC_{pi})$$
 (27.3-1)

• C&C: (h<60'):
$$p = q_h K_d [(GC_p) - (GC_{pi})] (lb/ft^2)$$
 (30.3-1)

• C&C (h>60'):
$$p = qK_{d}(GC_{p}) - q_{i}K_{d}(GC_{pi})(lb/ft^{2})$$
(30.4-1)

• Tornado MWFRS:
$$p_T = qG_T K_{dT} K_{vT} C_p - q_i (GC_{piT}) (lb/ft^2)$$
 (32.15-1)

• Tornado C&C (h<60'):
$$p_T = q_{hT} [K_{dT} K_{vT} (GC_p) - (GC_{piT})]$$
 (lb/ft²) (32.17-1)

• Tornado C&C (h>60'):
$$p_T = q K_{dT} K_{vT}(GC_p) - q_i(GC_{piT})$$
 (lb/ft²) (32.17-2)

Gust Effect Factor

- Table 26.11-1 adjustments
- 26.11.5 Flexible Buildings
 - Multiple clarifications to flexible gust effect factor, G_f, variables and equations

Table 26.11-1. Terrain Exposure Constants.

Velocity pressure			Customary Units Gust effect factor					
Exposure	α	z_g (ft)	â	ĥ	$\overline{\alpha}$	\bar{b}	e	l (ft)
B C D	7.5 9.8 11.5	3,280 2,460 1,935	1/7.5 1/9.8 1/11.5	0.84 1.00 1.09	1/4.5 1/6.4 1/8.0	0.47 0.66 0.78	0.30 0.20 0.15	320 500 650
			SI Units					
Exposure	α	z_g (m)	â	ĥ	$\overline{\alpha}$	\bar{b}	c	l (m)
B C D	7.5 9.8 11.5	1,000 750 590	1/7.5 1/9.8 1/11.5	0.84 1.00 1.09	1/4.5 1/6.4 1/8.0	0.47 0.66 0.78	0.30 0.20 0.15	97.54 152.40 198.12

^{*} z_{min} = Minimum height used to ensure that the equivalent height \(\bar{z}\) is the greater of 0.6h or z_{min}. For buildings or other structures as z_{min}.

Wind Borne Debris Region

- Definition change in 26.12.3.1
- Areas in hurricane prone region where:
 - $V \ge 140$ mph, or
 - V ≥ 130 mph & within 1 mile of the coastal mean high water line where an Exposure D condition exists upwind of the water line




Photo credit: FEMA P-2077 Mitigation Assessment Team

Report: Hurricane Michael in Florida

Main Wind Force Resisting System Chapter 27 & 28

MWFRS Tabular Methods

- Chapter 27 Part 2: Enclosed
 Simple Diaphragm Buildings
- Chapter 28 Part 2: Enclosed Simple Diaphragm Low-Rise Buildings
- Removed entirely



Pressure Equations: K_d

• K_d moved from Velocity Pressure (q_z) to Pressure Equations $q_z = 0.00265 K_z K_{zt} K_d K_e V^2$ (26.10-1)

• MWFRS:

$$p = q \mathbf{K_d} G C_p - q_i \mathbf{K_d} (G C_{pi}) \tag{27.3-1}$$

- New in ASCE 7-22!
 - MWFRS
 - C&C




- Check "blocked area" under structure
- Vertical cross section: blocked area less than 75% of gross area?
- Plan area: blocked area less than specified Plan percentages?

- Yes to both:
 - MWFRS Loads per 27.3.1.1.1
 27.3.1.1.2
- No to either:
 - Assume solid structure for MWFRS loads


L/B	Plan Area Blocked
<2.5	50%
3.0	45%
3.5	40%
4.0	36%
4.5	33%
5.0	30%

- Section 27.3.1.1.1:
 Elevated Building Loads
 - Roof & wall loads




Typical Elevated Tall Building - Elevation

- Section 27.3.1.1.2: Lateral Loads on Elements Below Elevated Building
 - Projected area of elements
 - Net force coefficient = 1.3
 - q_z elevation = h_1 + 0.25 h_2



Typical Elevated Tall Building - Elevation

- Section 27.3.1.1.3: External Loads on Horizontal Bottom Surfaces of the Elevated Building
 - Roof pressure coefficients (flat roof)
 - h = h₁ for windward edge zone
 (elevated level height)
 - q_z elevation = h_1 + 0.25 h_2



Typical Elevated Tall Building - Elevation

Load Cases

- Figure 27.3-8 revised
- Load direction clarified
- Use max, not combined roof load for Case 3 & 4
- Torsional moment
 application to flexible
 diaphragms clarified (Note 4)




Figure 27.3-8. Main wind force resisting system, design wind load cases.

Building Appurtenances & Other Structures Chapter 29

Pressure Equations: K_d

• K_d moved from Velocity Pressure (q_z) to F & P Equations $q_z = 0.00265 K_z K_{zt} K_d K_e V^2$ (26.10-1)

$$F = q_h K_d G C_s A_s \tag{29.3-1}$$

$$F = q_z K_d G C_f A_f \tag{29.4-1}$$

$$F_h = q_h \mathbf{K_d}(GC_r) A_f \tag{29.4-2}$$


$$F_{v} = q_{h} K_{d}(GC_{r}) A_{f} \qquad (29.4-3)$$

$$p = q_h \mathbf{K_d} \left(GC_p - \left(GC_{pi} \right) \right) \quad (29.4-4)$$

(not all Chapter 29 equations shown for brevity)

Solid Signs & Walls

- Figure 29.3-1
- Notes cleanup
- Clarify load cases
 - Case A & C: Always
 - Case B: Not required for B/s
 2 (ie signs 2x longer than height)



Notes

- Force coefficients for solid walls or signs with openings less than 30% of gross area shall be permitted to be multiplied by the reduction factor (1 – (1 – ε)^{1.5}).
- To allow for both normal and oblique wind directions, the following cases shall be considered: For s A < 1: (Elevated sign)
 - Case A: Resultant force acts normal to the face of the wall or sign through the geometric center.
 - Case B: Resultant force acts normal to the face of the wall or sign at a distance from the geometric center toward the windward edge equal to 0.2 times the average width of the wall or sign.

For double-faced signs with all sides enclosed and $R_{\text{max}} \le 0.4$, it is permitted to use force eccentricity, $e = (0.2 - 0.25R_{\text{max}})B$. For double-faced signs with all sides enclosed and $R_{\text{min}} \le 0.75$, it is permitted to multiply tabulated C_f values in Cases A and B by the reduction factor, $(1 - 0.133R_{\text{min}})$.

For $B/s \ge 2$, Case B need not be considered, while Case C must be considered;

Case C: Resultant forces act normal to the face of the wall or sign through the geometric centers of each region. For s/h = 1: (No legs)

The same cases as above except that the vertical locations of the resultant forces occur at a distance above the geometric center equal to 0.05 times the average height of the wall or sign.

- For Case C where s/h > 0.8, force coefficients shall be multiplied by the reduction factor (1.8 s/h). It is permitted to apply this reduction with those specified in Note 2.
- Linear interpolation is permitted for values of s/h, B/s, and L_r/s other than shown.

Roof Mount Solar

- Parallel to roof
 - Section 29.4.4
 - Pressure equalization reduction for certain conditions (Fig 29.4-8)




Photo credit: National Park Foundation

Figure 29.4-8. Solar panel pressure equalization factor, γ_a , for enclosed and partially enclosed buildings of all heights. *Note:* Bilinear interpolation between the solid line and the dashed line is permitted. Change to = signs for solid line.

Ground Mount Solar

- New section 29.4.5
- Adds guidance for fixed-tilt systems





Photo credit: Solar Energy Industries Association

Components & Cladding Chapter 30

Tabular Methods

- Removed from ASCE 7-22
- Moved to Guide to the Wind Load Provisions of ASCE 7-22
- Spreadsheets / Commercial software



Pressure Equations: K_d

• K_d moved from Velocity Pressure (q_z) to Pressure Equations $q_z = 0.00265 K_z K_{zt} K_d K_e V^2$ (26.10-1)

• C&C:


$$p = q_h \mathbf{K_d} [(GC_p) - (GC_{pi})]$$

$$p = q \mathbf{K_d} (GC_p) - q_i \mathbf{K_d} (GC_{pi})$$
(30.3-1)

- New in ASCE 7-22!
 - MWFRS
 - C&C



- Bottom Horizontal
 Surfaces of Elevated
 Buildings
 - Section 30.3.2.1: $h \le 60$ ft
 - Section 30.4.2.1: h > 60 ft



Elevated Buildings




Figure 30.3-1A. Components and cladding [$h \le 60$ ft (18.3 m)]: external pressure coefficient zones for enclosed, partially enclosed, and partially open elevated buildings with partially enclosed spaces and areas beneath the elevated building—bottom horizontal surface of elevated buildings.




Figure 30.4-1A. Components and cladding, part 3 [h > 60 ft (h > 18.3 m)]: external pressure coefficient zones for enclosed, partially enclosed, and partially open elevated buildings with partially enclosed spaces and areas beneath the elevated building—bottom horizontal surface of elevated buildings.

Roof External Pressure Coefficients (GC_p)

• Gable: Fig 30.3-2B – 2D

• Hip: Fig 30.3-2E – 2G

- ASCE 7-16: Ridge, eave, corner zones
- ASCE 7-22: Simplified!




Photo credit: FEMA P-2342 Mitigation Assessment Team Report:



Low-Rise Gable Roofs

External pressure coefficients, (GC_p)








Table C30.3-3. Gable Roof, $7^{\circ} < \theta \le 20^{\circ}$ (Figure 30.3-2B)

Positive with and without overhang					
All Zones	$(GC_p) = 0.7$	for $A \le 2$ ft ²			
	$(GC_p) = 0.7709 - 0.2354 \log A$	for $2 \le A \le 100 \text{ ft}^2$			
	$(GC_p) = 0.3$	for $A \ge 100 \text{ ft}^2$			
	Negative without overhang				
Zones 1	$(GC_p) = -2.0$	for $A \le 20$ ft ²			
and 2e	$(GC_p) = -4.7920 + 2.1460 \log A$	for $20 \le A \le 100 \text{ ft}^2$			
	$(GC_p) = -0.5$	for $A \ge 100 \text{ ft}^2$			
Zones 2n,	$(GC_p) = -3.0$	for $A \le 10$ ft ²			
2r, and 3e	$(GC_p) = -4.4307 + 1.4307 \log A$	for $10 \le A \le 250 \text{ ft}^2$			
	$(GC_p) = -1.0$	for $A \ge 250 \text{ ft}^2$			
Zone 3r	$(GC_p) = -3.6$	for $A \le 10$ ft ²			
	$(GC_p) = -5.4000 + 1.800 \log A$	for $10 \le A \le 100 \text{ ft}^2$			
	$(GC_p) = -1.8000$	for $A \ge 100 \text{ ft}^2$			
Negative with overhang					
Zones 1	$(GC_p) = -2.5$	for $A \le 20$ ft ²			
and 2e	$(GC_p) = -4.3614 + 1.4307 \log A$	for $20 \le A \le 100 \text{ ft}^2$			
	$(GC_p) = -1.5$	for $A \ge 100 \text{ ft}^2$			
Zones 2n	$(GC_p) = -3.5$	for $A \le 10$ ft ²			
and 2r	$(GC_p) = -4.5730 + 1.0730 \log A$	for $10 \le A \le 250 \text{ ft}^2$			
	$(GC_p) = -2.0$	for $A \ge 250 \text{ ft}^2$			
Zone 3e	$(GC_p) = -4.1$	for $A \le 10$ ft ²			
	$(GC_p) = -5.9599 + 1.8599 \log A$	for $10 \le A \le 250 \text{ ft}^2$			
	$(GC_p) = -1.5$	for $A \ge 250$ ft ²			
Zone 3r	$(GC_p) = -4.7$	for $A \le 10$ ft ²			
	$(GC_p) = -7.1000 + 2.4000 \log A$	for $10 \le A \le 100 \text{ ft}^2$			
	$(GC_p) = -2.3$	for $A \ge 100 \text{ ft}^2$			

Low-Rise Hip Roofs

- (GC_p) Function of h/B in ASCE 7-16
- ASCE 7-22: Simplified!








Table C30.3-6. Hip Roofs, No Overhang, 7°<0€20° (Figure 30.3-2E)

Positive $h/B > 0.8$					
	for $A \le 10$ ft ²				
	for $10 \le A \le 100 \text{ ft}^2$				
	for $A \ge 100 \text{ ft}^2$				
$(GC_p) = -1.8$	for $A \le 20$ ft ²				
$(GC_p) = -3.2891 + 1.1445 \log A$	for $20 \le A \le 100 \text{ ft}^2$				
$(GC_p) = -1.0$	for $A \ge 100 \text{ ft}^2$				
$(GC_p) = -2.4$	for $A \le 10$ ft ²				
$(GC_p) = -3.2455 + 0.8455 \log A$	for $10 \le A \le 200 \text{ ft}^2$				
	for $A \ge 200 \text{ ft}^2$				
	for $A \le 10$ ft ²				
	for $10 \le A \le 200 \text{ ft}^2$				
$(GC_p) = -1.4$	for $A \ge 200 \text{ ft}^2$				
Positive $h/B \leq 0.5$					
$(GC_p) = 0.7$	for $A \leq 10$ ft ²				
$(GC_p) = 1.1000 - 0.4000 \log A$	for $10 \le A \le 100 \text{ ft}^2$				
$(GC_p) = 0.3$	for $A \ge 100 \text{ ft}^2$				
Negative $h/B \leq 0.5$					
$(GC_p) = -1.3$	for $A \le 20$ ft ²				
$(GC_p) = -1.8584 + 0.4292 \log A$	for $20 \le A \le 100 \text{ ft}^2$				
$(GC_p) = -1.0$	for $A \ge 100 \text{ ft}^2$				
$(GC_p) = -2.4$	for $A \leq 10$ ft ²				
$(GC_p) = -3.2455 + 0.8455 \log A$	for $10 \le A \le 200 \text{ ft}^2$				
$(GC_p) = -1.3$	for $A \ge 200 \text{ ft}^2$				
$(GC_p) = -1.8$	for $A \le 10$ ft ²				
$(GC_p) = -2.3380 + 0.5380 \log A$	for $10 \le A \le 200 \text{ ft}^2$				
$(GC_p) = -1.1$	for $A \ge 200$ ft ²				
	$\begin{array}{c} (GC_p) = -3.2891 + 1.1445 \log A \\ (GC_p) = -1.0 \\ (GC_p) = -2.4 \\ (GC_p) = -3.2455 + 0.8455 \log A \\ (GC_p) = -1.3 \\ (GC_p) = -3.5223 + 0.9223 \log A \\ (GC_p) = -3.5223 + 0.9223 \log A \\ (GC_p) = -1.4 \\ \hline \textbf{Positive } h/B \leq \textbf{0.5} \\ (GC_p) = 0.7 \\ (GC_p) = 0.7 \\ (GC_p) = 0.3 \\ \hline \textbf{Negative } h/B \leq \textbf{0.5} \\ (GC_p) = -1.3 \\ (GC_p) = -1.3 \\ (GC_p) = -1.0 \\ (GC_p) = -1.0 \\ (GC_p) = -2.4 \\ (GC_p) = -2.4 \\ (GC_p) = -3.2455 + 0.8455 \log A \\ (GC_p) = -1.3 \\ (GC_p) = -1.3 \\ (GC_p) = -1.3 \\ (GC_p) = -2.4 \\ (GC_p) = -2.4 \\ (GC_p) = -2.4 \\ (GC_p) = -2.4 \\ (GC_p) = -2.3380 + 0.5380 \log A \\ (GC_p) = -1.8 \\ (GC_p) = -1.8 \\ (GC_p) = -1.8 \\ (GC_p) = -2.3380 + 0.5380 \log A \\ \end{array}$				


Low-Rise Hip Roofs

- ASCE 7-22 External pressure coefficients, (GC_p)
 - h/B removed
 - 27° 45° changed to θ = 45°
 - Interpolate between Figures 30.3-2G and -2F:

$$\frac{\left[GC_{p}(2G) - GC_{p}(2F)\right] * (\theta_{1} - 27^{\circ})}{(45^{\circ} - 27^{\circ})} + GC_{p}(2F)$$

Low-Rise Roof Overhangs


- (GC_p) Included only in $\theta \le$ 7° roof figure
 - Removed from gable & hip
- Section 30.7
 - Wall +(GC_p) on bottom surface
 - Roof -(GC_p) on top surface



Building Section

Low-Rise Arched Roofs

- Figure 30.3-8
 - Not new content; previously pointer to Chapter 27



Notation

- L = Horizontal dimension of building, ft (m), measured normal to ridge.
- r = Rise-to-span ratio = 'rise'/L.
- $h = \text{Roof height as defined in Chapter 26 for roof angle }\theta$.
- θ = Angle of plane of roof from horizontal, in degrees, measured at eave.

External Pressure Coefficient, GCp


Conditions	Rise-to-Span Ratio, r	(GC_p)	
	_	Zone A	Zone B
Roof on elevated	0 < r < 0.2	-1.08	-0.84-1.2r
structure		1.8r-0.36	
	$0.2 \le r < 0.3$	7.2r-2.52	-0.84-1.2r
		-0.6	
	$0.3 \le r \le 0.6$	3.3r-0.84	-0.84-1.2r
		-0.6	
Roof springing from	$0 < r \le 0.6$	1.68r	-0.84-1.2r
ground level	0 < r ≤ 0.0	-0.6	-0.84-1.27

Notes

- At roof perimeter Zone C, use the roof zones (Zone 2 and 3) and external pressure coefficients in Fig. 30.3-2A, B, C, and D with "0" based on springline slope. In the case of Fig. 30.3-2A, use 0.6h as the size of the roof perimeter Zone C. For roof Zones A and B, use external pressure coefficients shown in this table.
- 2. Plus and minus signs signify pressures acting toward and away from the surfaces, respectively.
- Where multiple values of (GC_p) are listed, the roof zone is subjected to either positive or negative pressures and the structure shall be designed for all conditions.


h > 60 ft Wall External Pressure Coeff (GC_p)

• Small EWA (GC_p) aligned with 10 ft²




Stepped Roofs

- Low roof at step:
 - Zone 2&3 negative ->Zone 1&2 negative
 - Zone 2 & 3 positive ->Zone 4 & 5 wall positive
- ASCE 7-22:
 - Same process as 7-16
 - Figure will be revised in Supplement



ASCE 7-16



ASCE 7-22

Stepped Roofs

Proposed Georgia
 Amendment




Figure 30.3-3. Components and cladding [$h \le 60$ ft ($h \le 18.3$ m)]: external pressure coefficients, (GC_p), for enclosed, partially enclosed, and partially open buildings, $\theta \le 7^\circ$ —stepped roofs.

Attached Canopies


- h ≤ 60 ft added in 7-16
- 7-22 adds h > 60 ft
- Separate (upper, lower)
 surfaces
- Net (combined upper + lower)



Attached Canopies

- h ≤ 60 ft added in 7-16
- 7-22 adds h > 60 ft
- Separate (upper, lower) surfaces
- Net (combined upper + lower)
 - Function of h_c/h_e

Diagram



Roof Pavers

- New in ASCE 7-22!
- Pedestal & loose laid pavers
- Not just "roofs"
 - Elevated amenity spaces
 - Balconies
- $p = q_h K_d C_{L_{net}}$
- $\bullet C_{L_{net}}$:
 - Roof (GC_p), wind tunnel data



Figure 1 – View of lifted pavers on the fifth floor roof. The red arrow indicates a paver resting on the top of the parapet.




Figure 5 - View of lifted pavers (Irwin 2012, Figure 5).

Wind Tunnel Procedure Chapter 31

Computational Fluid Dynamics (CFD)

- Section 31.1
 - CFD shall be validated by physical wind tunnel
 - Comply with ASCE 49
 - Peer review per Section1.3.1.3.4



Other Changes

- Guidance for:
 - Ground mounted solar 31.4.5
 - Loads for structures at multiple sites 31.5.1
 - Rooftop solar 31.5.2



Tornado Loads Chapter 32

Chapter 32

- New Chapter and Commentary
- Different from wind loads
- Subscript T or Tor
- Point back to Chapters 26-31 for applicable criteria

CHAPTER 32 TORNADO LOADS

32.1 PROCEDURES

32.1.1 Scope Buildings and other structures classified as Risk Category III or IV and located in the tomado-prone region as shown in Figure 32.1-1, including the main wind force resisting system (MWFRS) and all components and cladding (C&C) thereof, shall be designed and constructed to resist the greater of the tomado loads determined in accordance with the provisions of this chapter or the wind loads determined in accordance with Chapters 26 through 31, using the load combinations provided in Chapters 36 through 31, using the load combinations provided in Chapter 3.

User Note: The tornado loads specified in this chapter provide reasonable consistency with the reliability delivered by the existing criteria in Chapters 26 and 27 for MWFRS, and therefore are only required for Risk Category III and IV buildings and other structures (see Return Period discussion in Section 22.3.1 for more information). The tornado loads are based on tornado speeds using 1,700- and 3,000-year return periods for Risk Category III and IV, respectively (which are the same return periods using 1,700- and 3,000-year return 26). The tornado speed at any given geographic location will range from approximately Enhanced Fujita Scale EPO – EPC intensity, depending on the risk category and effective plan area of the building or other structure (see Section C32.5.1). Options for protection of life and property from more intense tornadoes include construction of a storm shelter and/or design for longer-return—period tornado speeds as provided in Appendix G, including performance-based design. A building or other structure design for tornado loads determined exclusively in accordance with Chapter 32 cannot be designated as a storm shelter without meeting additional critical requirements provided in the applicable building code and ICC 500, the ICCNSSA Standard for the Design and Construction of Storm Shelters. See Commentary Section C32.1.1 for an in-depth discussion on storm shelters.

32.1.2 Permitted Procedures The design tornado loads for buildings and other structures, including the MWFRS and C&C elements thereof, shall be determined using one of the procedures as specified in this section and subject to the applicable limitations of Chapters 26 through 32, excluding Chapter 28.

An outline of the overall process for the determination of the tornado loads, including section references, is provided in Figure 32.1-3.

32.1.2.1 Tornado Loads on the Main Wind Force Resisting System Tornado loads for the MWFRS shall be determined using one or more of the following procedures, as modified by Chanter 32:

- Directional Procedure for buildings of all heights as specified in Chapter 27 for buildings meeting the requirement specified therein;
- 2. Directional Procedure for Building Appurtenances (such as Directional Procedure for Building Appurtenances (such as solid freestanding walls and solid freestanding signs, chimneys, tanks, open signs, single-plane open frames, and trussed towers) as specified in Chapter 29 for buildings meeting the requirements specified thereing of 3. Wind Tunnel Procedure for all buildings and all other control of all buildings and all other control of the procedure for all buildings and all other control of the procedure for all buildings and all other control of the procedure for all buildings and all other control of the procedure for all buildings and all other control of the procedure for all buildings and all other control of the procedure for all buildings and all other control of the procedure for the procedure f
- Wind Tunnel Procedure for all buildings and all other structures as specified in Chapter 31 for buildings meeting the requirements specified therein.

32.1.2.2 Tornado Loads on Components and Cladding Tornado loads on the C&C of all buildings and other structures shall be determined using one or more of the following procedures, as modified by Chapter 32:

- Analytical Procedures as specified in Parts 1 through 5, as appropriate, of Chapter 30, for buildings or other structures meeting the requirements specified therein; or
- Wind Tunnel Procedure for all buildings and other structures as specified in Chapter 31, for buildings meeting the requirements specified therein.

32.1.3 Performance-Based Procedures Tomado design of buildings and other structures using performance-based procedures shall be permitted subject to the approval of the Authority Having Jurisdiction. The performance-based tornado design procedures used shall, at a minimum, conform to Section 1.3.1.3 and be documented and submitted to the Authority Having Jurisdiction in accordance with Section 1.3.1.3.

32.2 DEFINITIONS

The following definitions apply to the provisions of Chapter 32. Terms not defined in this chapter shall be defined in accordance with Chapters 26 through 31, as appropriate, excluding Chapter 28.

ASCE TORNADO DESIGN GEODATABASE: The ASCE database (version 2022-1.0) of geocoded tornado speed design

OTHER STRUCTURES, SEALED: A structure that is completely sealed or has controlled ventilation such that torna-do-induced atmospheric pressure changes will not be transmitted to the inside of the structure, including but not limited to certain tanks and vessels.

TORNADO-PRONE REGION: The area of the conterminous United States most vulnerable to tornadoes, as shown in Figure 32.1-1.

Minimum Design Loads and Associated Criteria for Buildings and Other Structures

353

Chapter 32

- Intended to improve resiliency and life safety
 - EFO EF2
- Higher levels of protection?
 - ICC 500 Storm Shelter
 - Longer return period tornado speeds (Appendix G)
 - Performance Based Design

CHAPTER 32 TORNADO LOADS

32.1 PROCEDURES

32.1.1 Scope Buildings and other structures classified as Risk Category III or IV and located in the tomado-ponce region as shown in Figure 32.1-1, including the main wind force resisting system (MWFRS) and all components and cladding (C&C) thereof, shall be designed and constructed in resist the greater of the tornado loads determined in accordance with the provisions of this chapter or the wind loads determined in accordance with Chapters 26 through 31, using the load combinations provided in Chapter 3.

User Note: The tornado loads specified in this chapter provide reasonable consistency with the reliability delivered by the existing criteria in Chapters 26 and 27 for MWFRS, and therefore are only required for Risk Category III and IV buildings and other structures (see Return Period discussion in Section C32-5.1 for more information). The tornado loads are based on tornado speeds using 1.700- and 3.000-year return periods for Risk Category III and IV, respectively (which are based on tornado speeds using 1.700- and 3.000-year return large from approximately Enhanced Fujiis Scale EFO – EF2 intensity, depending on the risk category and effective plan area of the building or other structure (see Section C32-5.1). Options for protection of life and property from more intense tornadoes include construction of a storm shelter and/or design for longer-return-period tornado-speeds as provided in Appendix G, including performance-based design. A mined exclusively in accordance with Chapter 32 cannot be designated as a storm shelter without meeting additional critical requirements provided in the applicable building code and ICC 300, the ICCNSSA Standard for the Design and Construction of Storm Shelters. See Commentary Section C32-3.1.1 for an in-depth discussion on storm shelters.

32.1.2 Permitted Procedures The design tornado loads for buildings and other structures, including the MWFRS and C&C elements thereof, shall be determined using one of the procedures as specified in this section and subject to the applicable limitations of Chapters 26 through 32, excluding Chapter 28.

An outline of the overall process for the determination of the tornado loads, including section references, is provided in Figure 32.1-3.

32.1.2.1 Tornado Loads on the Main Wind Force Resisting System Tornado loads for the MWFRS shall be determined using one or more of the following procedures, as modified by Chapter 32:

- Directional Procedure for buildings of all heights as specified in Chapter 27 for buildings meeting the requirement specified therein;
- 2. Directional Procedure for Building Appurtenances (such as borotop structures and rooftop equipment) and Other Structures (such as solid freestanding walls and solid freestanding signs, chimneys, tanks, open signs, single-plane open frames, and trussed towers) as specified in Chapter 29 for buildings meeting the requirements specified therein; or 3. Wind Tunnel Procedure for all buildings and all other control of the process of the designs of the process of the specified therein; or 3.
- Wind Tunnel Procedure for all buildings and all other structures as specified in Chapter 31 for buildings meeting the requirements specified therein.

32.1.2.2 Tornado Loads on Components and Cladding Tornado loads on the C&C of all buildings and other structures shall be determined using one or more of the following procedures, as modified by Chapter 32:

- Analytical Procedures as specified in Parts 1 through 5, as appropriate, of Chapter 30, for buildings or other structures meeting the requirements specified therein; or
- Wind Tunnel Procedure for all buildings and other structures as specified in Chapter 31, for buildings meeting the requirements specified therein.

32.1.3 Performance-Based Procedures Tomado design of buildings and other structures using performance-based procedures shall be permitted subject to the approval of the Authority Having Jurisdiction. The performance-based tomado design procedures used shall, at a minimum, conform to Section 1.3.1.3 and be documented and submitted to the Authority Having Jurisdiction in accordance with Section 1.3.1.3.

32.2 DEFINITIONS

The following definitions apply to the provisions of Chapter 32. Terms not defined in this chapter shall be defined in accordance with Chapters 26 through 31, as appropriate, excluding Chapter 28.

ASCE TORNADO DESIGN GEODATABASE: The ASCE database (version 2022-1.0) of geocoded tornado speed design

OTHER STRUCTURES, SEALED: A structure that is completely sealed or has controlled ventilation such that torna-do-induced atmospheric pressure changes will not be transmitted to the inside of the structure, including but not limited to certain tanks and vessels

TORNADO-PRONE REGION: The area of the conterminous United States most vulnerable to tornadoes, as shown in Figure 32.1-1.

Minimum Design Loads and Associated Criteria for Buildings and Other Structures

353

Risk Category III or IV




Figure 32.1-2. Flowchart of process for determining when design for tornado loads is required.

- Risk Category III or IV
- Tornado prone region






Figure 32.1-2. Flowchart of process for determining when design for tornado loads is required.

- Risk Category III or IV
- Tornado prone region





- Risk Category III or IV
- Tornado prone region
- $V_T > 60 \text{ mph}$
- $\bullet V_T >$
 - 0.5*V (Exposure B)
 - 0.6*V (Exposure C)
 - 0.67*V (Exposure D)





Figure 32.1-2. Flowchart of process for determining when design for tornado loads is required.


Tornado Basic Criteria




- Risk Category
- Effective Plan Area, A_e

- Risk Category
 - III = 1,700 year MRI
 - IV = 3,000 year MRI
- 8 maps for each Risk Category (III & IV):
 - 1 ft² (point target), 2,000 ft², 10,000 ft², 40,000 ft², 100,000 ft², 250,000 ft², 1,000,000 ft², 4,000,000 ft²
- $V_T = 50 124$ mph (Risk Category III)
- $V_T = 50 138$ mph (Risk Category IV)

- Risk Category
- Effective Plan Area, A_e




Individual Building




Essential Facilities with Functionally Dependent Structures

Tornado Speed, V_T: Risk Category III



- 5. Tornado speeds correspond to approximately a 3% probability of exceedance in 50 years (annual exceedance probability = 0.000588, MRI = 1,700 years).
- 6. Location-specific tornado speed is permitted to be determined using the ASCE Tornado Design Geodatabase, available at the ASCE 7 Hazard Tool (http://asce7hazardtool.online)


Figure 32.5-1C (Continued). Tornado speeds for Risk Category III buildings and other structures, for effective plan area of 10,000 ft2 (929 m2).



- 5. Tornado speeds correspond to approximately a 3% probability of exceedance in 50 years (annual exceedance probability = 0.000588, MRI = 1,700 years).
- 6. Location-specific tornado speed is permitted to be determined using the ASCE Tornado Design Geodatabase, available at the ASCE 7 Hazard Tool (http://asce/?hazardtool.online)


Figure 32.5-1E (Continued). Tornado speeds for Risk Category III buildings and other structures, for effective plan area of 100,000 ft2 (9,290 m2).

Tornado Speed, V_T: Risk Category IV




- 4. Islands, coastal areas, and land boundaries outside the last contour shall use the last tornado speed contour
- 5. Tornado speeds correspond to approximately a 1.7% probability of exceedance in 50 years (annual exceedance probability = 0.00033, MRI = 3,000 years).
- 6. Location-specific tornado speed is permitted to be determined using the ASCE Tornado Design Geodatabase, available at the ASCE 7 Hazard Tool (http://asce7hazardtool.online)

Figure 32.5-2C (Continued). Tornado speeds for Risk Category IV buildings and other structures, for effective plan area of 10,000 ft2 (929 m2).



- 4. Islands, coastal areas, and land boundaries outside the last contour shall use the last tornado speed contour
- 5. Tornado speeds correspond to approximately a 1.7% probability of exceedance in 50 years (annual exceedance probability = 0.00033, MRI = 3.000 years)
- 6. Location-specific tornado speed is permitted to be determined using the ASCE Tornado Design Geodatabase, available at the ASCE 7 Hazard Tool (http://asce7hazardtool.online)

Figure 32.5-2E (Continued). Tornado speeds for Risk Category IV buildings and other structures, for effective plan area of 100,000 ft2 (9,290 m2).



Tornado Directionality Factor, K_{dT}

- Sec 32.6 & Table 32.6-1
- Main Wind Force Resisting System

•
$$K_{dT} = 0.80$$

- Components & Cladding
 - K_{dT} = 1.0 Essential Facilities & buildings intended to remain operational
 - $K_{dT} = 0.90$ for Roof Zone 1'
 - $K_{dT} = 0.75$ for all other cases

Table 32.6-1. Tornado Directionality Factor, K_{dT}.

Structure Type	Tornado Directi
Buildings	
Main wind force resisting system	0.80
Components and cladding	
For Essential Facilities and for buildings and other structures required to maintain the functionality of Essential Facilities	1.0
Roof Zone 1' as shown in Figure 30.3-2A	0.90
All other cases	0.75
Arched roofs, circular domes, and all other structures	Use value fro

Tornado Velocity Pressure

- Sec 32.10 & Table 32.10-1
- No exposure category
- No topographic effects
- K_{zTor} & K_{hTor}
 - Constant up to 200 ft
- Velocity pressure:
 - $\bullet q_{zT} = 0.00256*K_{zTor}*K_e*V_T^2$

Table 32.10-1. Tornado Velocity Pressure Exposure Coefficients, K_{zTor} and K_{hTor} .

	Height above Ground Level, z or h	K _{zTor} and K _{hTor}
ft	m	
)-200	0-61.0	1.0
250	76.2	0.96
300	91.4	0.92
>328	>100	0.90

Notes:

 The tornado velocity pressure exposure coefficient, K_{cTarr} is permitted to be determined as follows:

For
$$0 < z \le 200$$
 ft (60 m) $K_{zTor} = 1.0$
For $200 < z \le 328$ ft $K_{zTor} = [(2820 - z)/2620]^2$, where z is in ft (For 61 < $z \le 100$ m) $K_{zTor} = [(861 - z)/800]^2$, where z is in m)
For $z > 328$ ft (100 m) $K_{zTor} = 0.90$

Linear interpolation for intermediate values of height z is permitted.

Tornado Gust Effects

- Sec 32.11
- $G_T = 0.85$ permitted for all structures
 - Option to calculate G per Chapter 26, use Exposure C

26.11.4 Rigid Buildings or Other Structures For rigid buildings or other structures as defined in Section 26.2, the gust-effect factor shall be taken as 0.85 or calculated by this formula:

$$G = 0.925 \left(\frac{1 + 1.7g_Q I_{\overline{Z}} Q}{1 + 1.7g_v I_{\overline{Z}}} \right)$$
 (26.11-6)

G_f does not apply to tornado loads

Tornado Enclosure Classification

- Sec 32.12
- Enclosure per Chapter 26
- Unprotected glazing on windward wall = openings for enclosure classification (32.12.2)
- Impact resistant glazing or impact-protection required for essential facilities (32.12.3)



Photo credit: FFMA

Tornado Internal Pressure Coefficient, GC_{piT}

- Sec 32.13 & Table 32.13-1
- GC_{piT} = +1.0 for sealed structures
- $GC_{piT} = +0.55$, -0.18 enclosed
- GC_{piT} = +0.55, -0.55 partially enclosed
- $GC_{piT} = +0.18$, -0.18 partially open
- $GC_{piT} = 0.00$ open

Table 32.13-1. Main Wind Force Resisting System and Components and Cladding Tornado Internal Pressure Coefficient, (GCpi7)


Enclosure Classification	Criteria for Enclosure Classification	Internal Pressure Combined with Atmospheric Pressure Change	Tornado Internal Pressure Coefficient, (GC _{pi7})
Sealed other structures	See Section 32.2	Extreme	+1.0
Enclosed buildings and other structures	See Table 26.13-1	High	+0.55
			-0.18
Partially enclosed buildings and other structures	See Table 26.13-1	High	+0.55
			-0.55
Partially open buildings and other structures	See Table 26.13-1	Moderate	+0.18
			-0.18
Open buildings and other structures	See Table 26.13-1	Negligible	0.00

Tornado Pressure Coeff Adjustment Factor, K_{vT}

- Sec 32.14 & Table 32.14-1
- Adjustment factor for vertical (uplift) loads
- K_{vT} = 1.10 for MWFRS Uplift pressure on roof
- K_{vT} = 1.05 1.30 for C&C (varies by roof slope and zone)

STRUCTURE TYPE $K_{\gamma T}$			
Buildings			
Negative (Uplift) Pressures on Roofs			
Main Wind Force Resisting System	1.1		
Components and Cladding	***		
Roof slope ≤ 7 degrees			
Zone 1	1.2		
Zone 2	1.05		
Zone 3	1.05		
Roof slope > 7 degrees			
Zone 1	1.2		
Zone 2	1.2		
Zone 3	1.3		
Positive Pressures (Downward Acting) on Roofs	1.0		
Wall Pressures	1.0		
All Other Cases	1.0		
Other Structures			
Negative (Uplift) Pressures on Rooftop Structures and			
Equipment and Rooftop Solar Panels Parallel to the Roof Surface			
Main Wind Force Resisting System	1.1		
Components and Cladding	Use values for building C&C		
Negative (Uplift) Pressures on Roofs of Bins, Silos, and Tanks			
Main Wind Force Resisting System	1.1		
Components and Cladding	See Section 32.17.5		
All Other Cases	1.0		


Tornado Loads: MWFRS



Tornado Loads: MWFRS

- 32.15.1 Enclosed, Partially Enclosed, and Partially Open Buildings
 - $p_T = q^*G_T^*K_{dT}^*K_{vT}^*C_p q_i(GC_{piT})$
 - •q = q_{7T} External pressure on all walls
 - •q = q_{hT} External pressure on roofs
 - • $q_i = q_{hT}$ Internal pressure on roofs (enclosed, partially open)
 - $\bullet q_i = q_{zT}$ Internal pressure on walls (enclosed, partially open)
 - • $q_i = q_{zop}$ Internal pressure on roofs, walls (partially enclosed)
 - FYI $q_{hT} = q_{zT}$ for $h \le 200$ ft!

Tornado Loads: Components & Cladding



Tornado Loads: Components & Cladding

• 32.17.1 Low-Rise Buildings

•
$$p_T = q_{hT}^* [K_{dT}^* K_{vT}^* (GC_p) - (GC_{piT})]$$

• 32.17.2 Buildings with h > 60 ft

•
$$p_T = q^* K_{dT}^* K_{vT}^* (GC_p) - q_i (GC_{piT})$$


Tornado Load Combos

- Chapter 2
- Strength Design
 - 1.2D + 1.0(W or W_T) + L + (0.5L_r or 0.3S or 0.5R)
 - $0.9D + 1.0(W \text{ or } W_T)$
- Allowable Stress Design
 - D + 0.6(W or W_T)
 - D + 0.75L + 0.75(0.6(W or W_T)) + 0.75($L_r \frac{or 0.75}{or 0.75}$ or R)
 - $0.6D + 0.6(W \text{ or } W_T)$

Tornado Load Design Example

Design Example


- Fire / Police Station
- Risk Category IV
- Cartersville, GA



- Wind Criteria
 - V = 117 mph
 - Exposure B
 - No Topographic Effects
 - $z_e = 750 \text{ ft}$
 - G = 0.85 (Rigid Building)
 - Enclosed Building
 - h = 24 ft
 - Flat roof


Tornado Criteria

- Effective plan area, $A_e = 24,000 \text{ ft}^2$
 - Includes auxiliary buildings that support functions of the essential facility (32.5.4.1)




Tornado Criteria

- Effective plan area, $A_e = 24,000 \text{ ft}^2$
 - Includes auxiliary buildings that support functions of the essential facility (32.5.4.1)
- $V_T = 86 + (\log 24,000 \log 10,000)x \frac{(90-86)}{(\log 40,000 \log 10,000)}$ = 88.5 mph




Verify Tornado Design Required

• Figure 32.1-2



Tornado Parameters



Tornado Parameters

•
$$A_e = 24,000 \text{ ft}^2$$

•
$$V_T = 89 \text{ mph}$$

- 0.80 MWFRS
- 1.0 C&C (Essential facility)

•
$$K_e = 0.97$$

•
$$K_{zTor} = K_{hTor} = 1.0$$

•
$$G_T = 0.85$$

Chapter 32: General Requirements. The basic parameters used in determination of tornado loads on both the MWFRS and C&C are

- \triangleright Tornado speed, V_T , see Section 32.5.1
- \triangleright Effective plan area, A_e , see Section 32.5.4
- \triangleright Tornado directionality factor, K_{dT} , see Section 32.6
- For Ground elevation factor, K_e , see Section 32.9
- Tornado velocity pressure exposure coefficients, K_{zTor} and K_{hTor} , see Section 32.10
- \triangleright Tornado gust effect factor, G_T , see Section 32.11
- Tornado enclosure classification, see Section 32.12
- \triangleright Tornado internal pressure coefficient, GC_{piT} , see Section 32.13
- Fornado pressure coefficient adjustment factor, K_{vT} , see Section 32.14.


Tornado Parameters

- Enclosed structure
 - Impact glazing required for essential facilities
- $GC_{piT} = +0.55, -0.18$
- K_{vT} =
 - 1.1 MWFRS Roof Uplift
 - 1.2 C&C Zone 1 Uplift
 - 1.05 C&C Zones 2 & 3 Uplift

Chapter 32: General Requirements. The basic parameters used in determination of tornado loads on both the MWFRS and C&C are

- \triangleright Tornado speed, V_T , see Section 32.5.1
- \triangleright Effective plan area, A_e , see Section 32.5.4
- \triangleright Tornado directionality factor, K_{dT} , see Section 32.6
- For Ground elevation factor, K_e , see Section 32.9
- \triangleright Tornado velocity pressure exposure coefficients, K_{zTor} and K_{hTor} , see Section 32.10
- \triangleright Tornado gust effect factor, G_T , see Section 32.11
- > Tornado enclosure classification, see Section 32.12
- \triangleright Tornado internal pressure coefficient, GC_{piT} , see Section 32.13
- Fornado pressure coefficient adjustment factor, K_{vT} , see Section 32.14.


Tornado Loads – MWFRS




Tornado Loads – MWFRS

Net Lateral Pressures (internal cancels)

		Wind	Tornado	
	Height	Pressure	Pressure	Tornado
Level	(ft)	(psf)	(psf)	/ Wind
High Roof	24	21.1	17.4	0.83
Low Roof	14	19.4	17.4	0.9






Building Section

Tornado Loads – MWFRS

Roof Uplift Pressures (positive internal) Wind Tornado Tornado / Distance from Pressure Pressure windward edge (psf) (psf) Wind 0 to h/2-18 -24.11.34 h/2 to h -24.1-18.0 1.34 h to 2h -11.5 (-16.0) -18.2 1.58 > 2h -8.3 (-16.0) -15.3 (-16.0) 1.84 (1.0)

Tornado Loads — C&C



Tornado Loads – C&C

Wall C&	C Pressu	res		
		Wind	Tornado	
EWA		Pressure	Pressure	Tornado
(ft ²)	Zone	(psf)	(psf)	/ Wind
10	4	-21.2	-30.4	1.44
	5	-26.0	-35.7	1.37
	Positive	19.5	21.3	1.09
100	4	-18.3	-27.3	1.49
	5	-20.3	-29.4	1.45
	Positive	16.7	18.2	1.09

Tornado Loads – C&C


Roof C&	C Pressu	res		
		Wind	Tornado	
EWA		Pressure	Pressure	Tornado
(ft ²)	Zone	(psf)	(psf)	/ Wind
10	1'	-19.5	-32.2	1.65
	1	-34.0	-51.1	1.50
	2	-44.9	-58.5	1.30
	3	-61.1	-77.2	1.26
	Positive	8.7 (<mark>16</mark>)	9.5 (<mark>16</mark>)	1.09 (1.0)

Tornado Loads – C&C

Roof C&	C Pressu	res		
		Wind	Tornado	
EWA		Pressure	Pressure	Tornado
(ft ²)	Zone	(psf)	(psf)	/ Wind
100	1'	-19.5	-32.2	1.65
	1	-26.6	-41.4	1.56
	2	-35.3	-47.5	1.35
	3	-42.0	-55.2	1.32
	Positive	6.9 (<mark>16</mark>)	7.5 (<mark>16</mark>)	1.09 (1.0)

Additional Examples


- NCSEA Wind Engineering Committee
 Example Problems
 - RC III School & RC IV Hospital
 - Free download from NCSEA.COM -> Education
 & Events-> Publications -> FAQ's & White Papers
- FEMA/NIST Design Guide for New Tornado Load Requirements in ASCE 7-22
 - RC IV Hospital
 - Free download from FEMA.GOV



FEMA NIST

Tornado Key Takeaways

- ASCE 7-22 Tornado Provisions
 - Improve resiliency & life safety
 - EFO EF2
 - Buildings are <u>NOT</u> storm shelters!
- Design Impacts
 - Low rise buildings
 - Interior roof zone uplift
 - Wall C&C pressures



Tornado Key Takeaways

- Construction Cost Impacts:
 - •< 0.25% Increase
 - NIST Technical Note 2214



Tornado Loads FAQ


How do I document tornado design?

- IBC 1603.1.4: Wind and tornado design data
 - Tornado speed, V_T
 - Effective plan area, A_e
 - Tornado internal pressure coefficients
 - C&C pressures: "...maximum of wind or tornado..."

GROUND SNOW LOAD, Pg	0 PSF
DESIGN WIND LOAD:	
ULTIMATE DESIGN WIND SPEED (3 SECOND GUST), Vult	201 MPH
NOMINAL DESIGN WIND SPEED, Vasd	156 MPH
RISK CATEGORY	IV
WIND EXPOSURE CATEGORY	D
COMPONENTS AND CLADDING WIND PRESSURE	SEE SCHEDULE
INTERNAL PRESSURE COEFFICIENT	0
DESIGN TORNADO LOAD: (PER FBC REQUIREMENTS)	
TORNADO SPEED (3 SECOND GUST), Vt	113 MPH
EFFECTIVE PLAN AREA FOR TORNADO DESIGN, Ae	4,000,000
RISK CATEGORY	IV
COMPONENTS AND CLADDING TORNADO PRESSURE	SEE SCHEDULE
TORNADO INTERNAL PRESSURE COEFFICIENTS	+1.0
DESIGN SEISMIC LOAD:	
DISK CATECODY	IV/

Renovations: Do tornado loads apply?


- Follow IEBC requirements associated with scope of work
- No "catch all" requirement
- "...satisfy the requirements of Section 1609 of the IBC..."
 - Includes tornado loads



rasi 906.3 Seismic Design Category F. 6

Renovations: Do tornado loads apply?

- Tornado design may apply for:
 - Major repairs
 - Alterations: Level 2 or 3
 - Substantial structural alterations
 - Change of occupancy (increase risk category)
 - Additions where not structurally independent
 - Relocated buildings



- 2. Where the intended alteration involves only the lowest story of a building, structural components of the lateral load resisting



Where buildings are undergoing Level 3 alterations, the provisions of this section shall apply

Building has a shelter, can I ignore Ch. 32?

- ICC 500:
 - FEMA P-361: ...safe room that provides **near-absolute protection**...for occupants.
 - Shelters are often limited to small areas of the overall building



Building has a shelter, can I ignore Ch. 32?

• ASCE 7:


 Improved resiliency and life safety in lower intensity tornadoes

- Applies to entire structure
- ASCE 7-22 Chapter 32 applies,
 even if there is a shelter



What's the deal with the impact glazing?

- ASCE 7 Sec 32.12.3:
 - Use ASTM E1996 Tables 2 & 3
 - Select wind zone using V_T in place of V
- Lowest wind zone is 130 mph, but $V_T < 130$?



What's the deal with the impact glazing?

- ASCE 7-22 Supplement 3 proposal:
 - Use ASTM E1996 Tables 2 & 3
 - Select wind zone using V₊ in place of V
 - Use missile level D as described in Table
 2 of ASTM E1996
 - Comply with impact pass/fail criteria for Enhanced Protection (Section 7 ASTM E1996)

Missile Level	Missile	Impact (m	
A	2 g (31 grains) ± 5 % steel ball	39.62 (130 f/s
В	910 g \pm 100 g (2.0 lb \pm 0.25 lb) 2 × 4 in. 52.5 cm \pm 100 mm (1 ft $-$ 9 in. \pm 4 in.) lumber	15.25 ((50 f/s
С	2050 g \pm 100 g (4.5 lb \pm 0.25 lb) 2 \times 4 in. 1.2 m \pm 100 mm (4 ft \pm 4 in.) lumber	12.19 ((40 f/s
D	4100 g ± 100 g (9.0 lb ± 0.25 lb) 2 × 4 in. 2.4 m ± 100 mm (8 ft ± 4 in.) lumber	15.25 ((50 f/s
Е	4100 g ± 100 g (9.0 lb ± 0.25 lb) 2 × 4 in. 2.4 m ± 100 mm (8 ft ± 4 in.) lumber	24.38 ((80 f/s
	^ ^		
impact protec	TABLE 3 Description Levels or Mesiles B, C, D, and E, also ase Missi tive systems (see 8.5).	le A for	pore
	or Mesiles B, C, D, and E, also ase Missi tive systems (see 8.5). Enhanced Protection Posic Protection	le A for Unprot	_
impact protect Level of	or Mesiles B, C, D, and E, also ase Missi tive systems (see 8.5). Enhanced Protection (Espential Facilities) Basic Protection ation =9.1 m >9.1 m >9.1 m >9.1 m :	Unprot ≤9.1 m	ected
impact protect Level of Protection	or Mesiles B, C, D, and E, also ase Missi tive systems (see 8.5). Enhanced Protection (Espential Facilities) Basic Protection ation =9.1 m >9.1 m >9.1 m >9.1 m >9.1 m >9.1 m	Unprot	ected
Level of Protection Assembly Eleve	or Missiles B, C, D, and E, also ase Missilive systems (see 8.5). Enhanced Protection (Escential Facilities) ation = 9.1 m	Unprot ≤9.1 m (30 ft)	ected >9.1 (30 f

